Date Submitted: 2/6/2018

WS County: PEND OREILLE



Water Use Efficiency **Annual Performance Report - 2017**

Water System ID# : 72752

WS Name: **RIVER BEND WATER SYSTEM**

Report submitted by: Mark Scott

Meter Installation Information:

Estimate the percentage of metered connections: 100%

If not fully metered - Current status of meter installation:

Production, Authorized Consumption, and Distribution System Leakage Information:

12/01/2016 To 12/01/2017 12-Month WUE Reporting Period: No Incomplete or missing data for the year? If yes, explain:

Distribution System Leakage Summary:

Total Water Produced and Purchased (TP) – Annual Volume Authorized Consumption (AC) - Annual Volume Distribution System Leakage - Annual Volume TP - AC Distribution System Leakage – Percent DSL = $[(TP - AC) / TP] \times 100$ 3-year annual average

Goal-Setting Information:

12/06/2016 Date of Most Recent Public Forum: Has goal been changed since last performance report? No Note: Customer goal must be re-established every 6 years through a public process

WUE Goals:

Customer Goal (Demand Side):

Reduce Water Consumption/Outdoor Water by 1% per year through 2022.

Describe Progress in Reaching Goals:

Customer (Demand Side) Goal Progress:

Increased public education to encourage water conservation and leak detection through the water newsletter, the Districts webpage, the annual consumer confidence reports, brochures, handouts, and other conservation information.

Continue to repair leaks as detected. Continue to evaluate water rate structures with emphasis on water conservation.

3,486,246 gallons 3,283,178 gallons 203,068 gallons 5.8 % 6.3 %

Additional Information Regarding Supply and Demand Side WUE Efforts

Include any other information that describes how you and your customers use water efficiently:

Increased public education to encourage water conservation and leak detection through the water newsletter, the Districts webpage, the annual consumer confidence reports, brochures, handouts, and other conservation information.

Continue to repair leaks as detected. Continue to evaluate water rate structures with emphasis on water conservation.

Do not mail, fax, or email this report to DOH